



California Sportfishing Protection Alliance

"An Advocate for Fisheries, Habitat, and Water Quality"

3536 Rainier Avenue, Stockton, CA 95204

T: 209-464-5067, F: 209-464-1028, E: deltakeep@aol.com, W: www.calsport.org

7 September 2008

Mr. Ken Landau, Asst. Executive Officer
Mr. Jim Marshall, Sr. WRCE
Ms. Gayleen Perreira, WRC Eng.
Regional Water Quality Control Board
Central Valley Region
11020 Sun Center Drive, Suite 200
Rancho Cordova, CA 95670-6144

VIA: Electronic Submission
Hardcopy if Requested

RE: Renewal of Waste Discharge Requirements (NPDES No. CA0079138) and Time Schedule Order for City of Stockton Regional Wastewater Control Facility, San Joaquin County

Dear Messrs. Landau, Marshall and Ms. Perreira,

The California Sportfishing Protection Alliance (CSPA) has reviewed the proposed Waste Discharge Requirements (Permit) for the City of Stockton Regional Wastewater Control Facility and submits the following comments.

CSPA requests status as a designated party for this proceeding. CSPA is a 501(c)(3) public benefit conservation and research organization established in 1983 for the purpose of conserving, restoring, and enhancing the state's water quality and fishery resources and their aquatic ecosystems and associated riparian habitats. CSPA has actively promoted the protection of water quality and fisheries throughout California before state and federal agencies, the State Legislature and Congress and regularly participates in administrative and judicial proceedings on behalf of its members to protect, enhance, and restore California's degraded water quality and fisheries. CSPA members reside, boat, fish and recreate in and along waterways throughout the Central Valley, including San Joaquin County.

- 1. Contrary to the Findings in the Proposed Permit, there are no limitations for toxicity, as required by federal regulations 40 CFR 122.44 (d), to achieve compliance with WQLSs for unknown toxicity in the receiving stream. The Proposed Permit does not contain effluent limitations for Chronic Toxicity And therefore fails to comply with federal regulations at 40 CFR 122.44 (d)(1)(I) and the *Policy For Implementation Of Toxics Standards For Inland Surface Waters, Enclosed Bays, And Estuaries Of California (SIP)*. The Proposed Permit also contains an acute toxicity discharge limitation that 30% mortality, thereby granting a mixing zone absent any required analysis**

The proposed Permit, Finding H, properly cites that the receiving stream, the San Joaquin River is a *Water Quality Limited Segment* (WQLSs) for unknown toxicity. The proposed Permit, Findings G and H, also properly cites that Federal Regulation 40 CFR 122.44 (d) requires that permit are required to contain limitations more stringent than technology based limitations where necessary to achieve applicable water quality standards and to achieve compliance in WQLSs. Proposed Permit Finding H is incorrect however in citing that toxicity limitations are included in the proposed Permit. The proposed Permit, *C Special Provisions 2 Special Studies, Technical Reports and Additional Monitoring Requirements, a, Chronic Whole Effluent Toxicity*, requires: “For compliance with the Basin Plan’s narrative toxicity objective, this Order requires the Discharger to conduct chronic whole effluent toxicity testing...” Sampling does not limit the discharge and does not constitute a limitation. Contrary to the Findings in the proposed Permit there are not limitations for toxicity although required by Federal Regulations 40 CFR 122.44 (d) to achieve compliance with WQLSs for unknown toxicity in the receiving stream.

Proposed Permit, State Implementation Policy states that: “On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.”

The SIP, Section 4, Toxicity Control Provisions, Water Quality-Based Toxicity Control, states that: “A chronic toxicity effluent limitation is required in permits for all dischargers that will cause, have a reasonable potential to cause, or contribute to chronic toxicity in receiving waters.” The SIP is a state *Policy* and CWC Sections 13146 and 13247 require that the Board in carrying out activities which affect water quality shall comply with state policy for water quality control unless otherwise directed by statute, in which case they shall indicate to the State Board in writing their authority for not complying with such policy.

Federal regulations, at 40 CFR 122.44 (d)(1)(i), require that limitations must control all pollutants or pollutant parameters which the Director determines are or may be discharged at a level which will cause, or contribute to an excursion above any State water quality standard, including state narrative criteria for water quality. There has been no argument that domestic sewage contains toxic substances and presents a reasonable potential to cause toxicity if not properly treated and discharged. The Water Quality Control Plan for the Sacramento/ San Joaquin River Basins (Basin Plan), Water Quality

Objectives (Page III-8.00) for Toxicity is a narrative criteria which states that all waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life. The Proposed Permit states that: "...to ensure compliance with the Basin Plan's narrative toxicity objective, the discharger is required to conduct whole effluent toxicity testing...". However, sampling does not equate with or ensure compliance. The Tentative Permit requires the Discharger to conduct an investigation of the possible sources of toxicity if a threshold is exceeded. This language is not a limitation and essentially eviscerates the Regional Board's authority, and the authority granted to third parties under the Clean Water Act, to find the Discharger in violation for discharging chronically toxic constituents. An effluent limitation for chronic toxicity must be included in the Order. In addition, the Chronic Toxicity Testing Dilution Series should bracket the actual dilution at the time of discharge, not use default values that are not relevant to the discharge.

Proposed Permit is quite simply wrong; by failing to include effluent limitations prohibiting chronic toxicity the proposed Permit does not "...implement the SIP." The Regional Board has commented time and again that no chronic toxicity effluent limitations are being included in NPDES permit until the State Board adopts a numeric limitation. The Regional Board explanation does not excuse the proposed Permit's failure to comply with Federal Regulations, the SIP, the Basin Plan and the CWC. The Regional Board's Basin Plan, as cited above, already states that: "...waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses..." Accordingly, the proposed Permit must be revised to prohibit chronic toxicity (mortality and adverse sublethal impacts to aquatic life, (sublethal toxic impacts are clearly defined in EPA's toxicity guidance manuals)) in accordance with Federal regulations, at 40 CFR 122.44 (d)(1)(i) and the Basin Plan and the SIP.

Under the federal Clean Water Act (CWA), states are required to classify surface waters by *uses* – the beneficial purposes provided by the waterbody. For example, a waterbody may be designated as a drinking water source, or for supporting the growth and propagation of aquatic life, or for allowing contact recreation, or as a water source for industrial activities, or all of the above. States must then adopt *criteria* – numeric and narrative limits on pollution, sufficient to protect the uses assigned to the waterbody. Federal regulations, at 40 CFR 122.44 (d)(1)(i), adopted to require implementation of the CWA, require that limitations must control all pollutants or pollutant parameters which the Director determines are or may be discharged at a level which will cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality. The Water Quality Control Plan for the Sacramento/ San Joaquin River Basins (Basin Plan), Water Quality Objectives (Page III-8.00), for Toxicity is a narrative criteria which states that all waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life and as stated above the receiving stream is a WQLS for unknown toxicity. This section of the Basin Plan further states, in part that, compliance with this objective will be determined by analysis of indicator organisms (toxicity tests).

The proposed Permit requires that the Discharger conduct acute toxicity tests and states that compliance with the toxicity objective will be determined by analysis of indicator organisms. However, the Tentative Permit contains a discharge limitation that allows 30% mortality (70% survival) of fish species in any given toxicity test. Surely, mortality is a detrimental physiological response to aquatic life.

In receiving streams where dilution may be available the primary mixing area is commonly referred to as the zone of initial dilution, or ZID. Within the ZID acute aquatic life criteria are exceeded. To satisfy the CWA prohibition against the discharge of toxic pollutants in toxic amounts, regulators assume that if the ZID is small, significant numbers of aquatic organisms will not be present in the ZID long enough to encounter acutely toxic conditions. The allowance of 30% mortality will result in acute toxicity within the ZID. Before the discharge can be allowed a complete mixing zone analysis is required in accordance with the Basin Plan and the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (SIP) to show that discharge limitations prevent toxicity; such an analysis has not been completed. CWC Sections 13146 and 13247 require that the Board in carrying out activities which affect water quality shall comply with state policy for water quality control unless otherwise directed by statute, in which case they shall indicate to the State Board in writing their authority for not complying with such policy. The State Board has adopted the SIP and the Regional Board is required to the Policy.

US EPA's *Technical Support Document for Water Quality-based Toxics Control* states, on page 104, that:

“When setting a whole effluent toxicity limit to protect against acute effects, some permitting authorities use an end-of-pipe approach. Typically these limits are established as an LC50>100% effluent at the end of the pipe. These limits are routinely set without any consideration as to the fate of the effluent and the concentrations of toxicant(s) after the discharge enters the receiving water. Limits derived in this way are not water quality based limits and suffer from significant deficiencies since the toxicity of a pollutant depends mostly upon concentration, duration of exposure, and repetitiveness of the exposure. This is especially true in effluent dominated waters. For example, an effluent that has an LC50=100% contains enough toxicity to be lethal up to 50% of the test organisms. If the effluent is discharged to a low flow receiving waterbody that provides no more than a three fold dilution at the critical flow, significant mortality can occur in the receiving water. Furthermore, such a limit could not assure protection against chronic effects in the receiving waterbody. Chronic effects could occur if the dilution in the receiving water multiplied by the acute to chronic ratio is greater than 100 percent. Therefore, in effluent dominated situations, limits set using this approach may be severely underprotective. In contrast, whole

effluent toxicity limits set using this approach in very high receiving water flow conditions may be overly restrictive.”

Following US EPA’s rationale the limitations of allowing 70% survival (30% mortality) in acute toxicity tests, as is the case in the cited LC50, will result in the allowance of toxic discharges to ephemeral streams, which is representative of the receiving waters at Davis. While the State and Regional Board’s method of prescribing an effluent limitation of 70% percent survival may be protective in waterbodies with significant dilution; such a limitation should be subject to a complete mixing zone analysis. For an ephemeral receiving stream a mixing zone analysis would not be applicable under worst-case dry stream conditions. The Order should be revised to require the Regional Board to prohibit acute toxicity (100% survival as compared to the laboratory control) in accordance with Federal regulations, at 40 CFR 122.44 (d)(1)(i).

With regard to WET testing variability; US EPA’s *Technical Support Document for Water Quality-based Toxics Control* states, on page 11, that:

“In summary, whole effluent toxicity testing can represent practical tests that estimate potential receiving water impacts. Permit limits that are developed correctly from whole effluent toxicity tests should protect biota if the discharged effluent meets the limits. It is important not confuse permit limit variability with toxicity test variability” (emphasis added)

The proposed Permit must be revised to prohibit acute toxicity, require 100% survival in toxicity tests, in accordance with Federal regulations, at 40 CFR 122.44 (d)(1)(i), the CWA, the SIP, the CWC and the Basin Plan.

2. The Proposed Permit does not meet the requirements for an exemption from California Code of Regulations (CCR) Title 27, does not meet the requirements of the Board’s Antidegradation Policy and Does not contain discharge limitations that prevent groundwater degradation or pollution in violation of California Water Code Section 13377

The Discharger’s wastewater treatment plant includes unlined facultative ponds and wetlands. “Groundwater monitoring results obtained within the Facility have at times exceeded the applicable water quality objectives for TDS and Nitrate” (page 24). The Groundwater data, Table F-13, shows that very few constituents have been monitored, however; the groundwater has been degraded by the discharge for TDS and EC. It is not necessary to determine unaffected background water quality to show degradation from the discharge. The proposed Permit, *B Groundwater Limitations 2*, states that the limitations for the protection of groundwater do not become effective until after completion of tasks outlined in Provision VI.C.2.c. Provision VI.C.2.c allows 2.5 years to complete a study of background water quality after which an assessment of best practicable treatment and control of the discharge will be assessed under an undefined time schedule. It is reasonable to assume that the Discharger could use the 5-year life of

the permit to conduct the studies required in Provision VI.C.2.c. There currently are no effective limitations in the proposed Permit protective of groundwater quality. California Water Code, section 13377, requires that: “Notwithstanding any other provision of this division, the state board and the regional boards shall, as required or authorized by the Federal Water Pollution Control Act, as amended, issue waste discharge and dredged or fill material permits which apply and ensure compliance with all applicable provisions of the act and acts amendatory thereof or supplementary, thereto, together with any more stringent effluent standards or limitations necessary to implement water quality control plans, or for the protection of beneficial uses, or to prevent nuisance.” Failure to include effective limitations for the protection of groundwater quality violates the requirements of CWC 13377.

CCR Title 27 §20090. SWRCB – allows for the following exemption (C15: §2511): The following activities shall be exempt from the SWRCB-promulgated provisions of this subdivision, so long as **the activity meets, and continues to meet, all preconditions listed:** (a) **Sewage**—Discharges of domestic sewage or treated effluent which are regulated by WDRs issued pursuant to Chapter 9, Division 3, Title 23 of this code, or for which WDRs have been waived, and which are **consistent with applicable water quality objectives**, and treatment or storage facilities associated with municipal wastewater treatment plants, **provided that residual sludges or solid waste from wastewater treatment facilities shall be discharged only in accordance with the applicable SWRCB-promulgated provisions of this division.** Region 5’s Basin Plan, Water Quality Objectives For Ground Waters, The following objectives apply to all ground waters of the Sacramento and San Joaquin River Basins, as the objectives are relevant to the protection of designated beneficial uses. These objectives do not require improvement over naturally occurring background concentrations.

Bacteria

In ground waters used for domestic or municipal supply (MUN) the most probable number of coliform organisms over any seven-day period shall be less than 2.2/100 ml.

Chemical Constituents

Ground waters **shall not contain chemical constituents in concentrations that adversely affect beneficial uses.** At a minimum, ground waters designated for use as domestic or municipal supply (MUN) **shall not contain concentrations of chemical constituents in excess of the maximum contaminant levels (MCLs) specified in the following provisions of Title 22 of the California Code of Regulations,** which are incorporated by reference into this plan: Tables 64431-A (Inorganic Chemicals) and 64431-B (Fluoride) of Section 64431, Table 64444-A (Organic Chemicals) of Section 64444, and Tables 64449-A (Secondary Maximum Contaminant Levels- Consumer Acceptance Limits) and 64449-B (Secondary Maximum Contaminant Levels-Ranges) of Section 64449. This incorporation-by-reference is prospective, including future changes to the incorporated provisions as the changes take effect. At a minimum, water designated for use as domestic or municipal supply (MUN) shall not contain lead

in excess of 0.015 mg/l. To protect all beneficial uses, the Regional Water Board may apply limits more stringent than MCLs.

Tastes and Odors

Ground waters shall not contain taste- or odor producing substances in concentrations that cause nuisance or adversely affect beneficial uses.

Toxicity

Ground waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life associated with designated beneficial use(s). This objective applies regardless of whether the toxicity is caused by a single substance or the interactive effect of multiple substances.

Based on the Findings in the proposed Permit it is clear that the Regional Board does not know if the discharge of domestic sewage at the City of Stockton meets, and continues to meet, all preconditions listed in Title 27; specifically whether the discharge is consistent with applicable water quality objectives. The discharge is not exempt from the requirements of CCR Title 27 since the “preconditions” required for an exemption cannot be established.

California Water Code Sections 13146 and 13247 require that the Board in carrying out activities which affect water quality shall comply with state policy and assure that Wastewater Dischargers are required to provide Best Practicable Treatment and Control (BPTC) of the discharge to assure pollution will not occur and that the highest water quality consistent with the maximum benefit to the people of the State will be maintained in accordance with the Antidegradation Policy (Resolution 68-16).

BAT and BPTC are terms applied with regulations on limiting pollutant discharges with regard to the abatement strategy. Similar terms are best available techniques, best practicable means or best practicable environmental option. The term constitutes a moving target on practices, since developing societal values and advancing treatment techniques may change what is currently regarded as achievable, best practicable and best available. A literal understanding will connect it with a “spare no expense” doctrine, which prescribes the acquisition of the best state of the art technology available, without regard for traditional cost-benefit analysis.

The Antidegradation Policy, State Water Resources Control Board Resolution No. 68-16, states that: “Any activity which produces or may produce a waste or increased volume or concentration of waste and which discharges or proposes to discharge to existing high quality waters will be required to meet waste discharge requirements which will result in the best practicable treatment or control of the discharge necessary to assure that (a) a pollution or nuisance will not occur and (b) the highest water quality consistent with the maximum benefit to the people of the State will be maintained.”

CWC Sections 13146 and 13247 require that the Board in carrying out activities which affect water quality shall comply with state policy for water quality control unless otherwise directed by statute, in which case they shall indicate to the State Board in writing their authority for not complying with such policy. The State Board has adopted the Antidegradation Policy (Resolution 68-16), which the Regional Board has incorporated into its Basin Plan. The Regional Board is required by the CWC to comply with the Antidegradation Policy. Waste Discharge Requirements must require that the treatments systems provide BPTC.

As stated above the Antidegradation Policy requires that any activity which produces or may produce a waste or increased volume or concentration of waste and which discharges or proposes to discharge to existing high quality waters will be required to meet waste discharge requirements which will result in the best practicable treatment or control of the discharge necessary to assure that pollution will not occur. Pollution is defined in CWC Section 13050 as: "...an alteration of the quality of the waters of the state by waste to a degree which unreasonably affects either of the following: a) the waters for beneficial uses, b) facilities which serve these beneficial uses. Pollution may also include contamination, which is defined as an impairment of the quality of the waters of the state to a degree that creates a hazard to the public health through poisoning or through the spread of disease. In short; the Regional Board is required to write waste discharge requirements that result in BPTC to assure that pollution will not occur and all beneficial uses are fully protected. The proposed Permit does not meet the test required by the Antidegradation Policy.

3. The proposed Permit does not contain an Effluent Limitation for oil and grease in violation of Federal Regulations 40 CFR 122.44 and California Water Code, Section 13377. The proposed Permit contains Effluent Limitations less stringent than the existing permit contrary to the Antibacksliding requirements of the Clean Water Act and Federal Regulations, 40 CFR 122.44 (I)(1)

The proposed Permit is for a domestic wastewater treatment plant. The existing NPDES Permit contained effluent limitations for oil and grease. Domestic wastewater treatment plants, by their nature, receive oil and grease in concentrations from home cooking and restaurants that present a reasonable potential to exceed the Basin Plan water quality objective for oil and grease (Basin Plan III-5.00). Confirmation sampling is not necessary to establish that domestic wastewater treatment systems contain oil and grease in concentrations that present a reasonable potential to exceed the water quality objective. It is not unusual for sewerage systems to allow groundwater cleanup systems, such as from leaking underground tanks, to discharge into the sanitary sewer. Groundwater polluted with petroleum hydrocarbons can also infiltrate into the collection system as easily as sewage exfiltrates. The Central Valley Regional Board has a long established history of including oil and grease limitations in NPDES permits at 15 mg/l as a daily maximum and 10 mg/l as a monthly average, which has established BPTC for POTWs.

The California Water Code (CWC), Section 13377 states in part that: "...the state board or the regional boards shall...issue waste discharge requirements...which apply and ensure compliance with ...water quality control plans, or for the protection of beneficial uses..." Section 122.44(d) of 40 CFR requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. Where numeric water quality objectives have not been established, 40 CFR §122.44(d) specifies that WQBELs may be established using USEPA criteria guidance under CWA section 304(a), proposed State criteria or a State policy interpreting narrative criteria supplemented with other relevant information, or an indicator parameter. Failure to include an effluent limitation for oil and grease in the proposed permit violates 40 CFR 122.44 and CWC 13377.

Notwithstanding the fact that the Regional Board has an established history of including oil and grease limitations in NPDES permits at 15 mg/l as a daily maximum and 10 mg/l as a monthly average, we believe these limitations are not necessarily protective. The only guidance we were able to find supporting the 15/10 mg/l limit is an old 1974 EPA memo discussing technological-based limits for stormwater runoff from petroleum refineries and marketing terminals. The 15/10 mg/l standard is clearly inadequate in situations where reasonable potential analyses mandate a water quality-based limitation.

Oil and grease is highly toxic to aquatic life: toxic at concentrations as low as 0.1 mg/L and sublethal toxicities are reported at 10-100 μ g/L. In fact, it has been shown that petroleum products can harm aquatic life at concentrations as low as 1 μ g/l. Oil and grease is also persistent, bioaccumulative and highly toxic in sediment. The US EPA's water quality standard for oil and grease is stated as: "a) 0.01 of the lowest continuous flow 96-hour LC50 to several important freshwater and marine species, each having a demonstrated high susceptibility to oils and petrochemicals, b) Levels of oils or petrochemicals in the sediment which cause deleterious effects to the biota should not be allowed and c) surface waters shall be virtually free from floating nonpetroleum oils of vegetable or animal origin, as well as petroleum-derived oils" Goldbook, 1986, Quality Criteria for Water, EPA 440/5-86-001. A table summarizing lethal toxicities of various petroleum products to aquatic life can be found in EPA's 1976 Quality Criteria for Water (Redbook, pp 210-215). The Basin Plan's narrative limit for oil and grease is stated as "[w]aters shall not contain oils, greases, waxes, or other materials in concentrations that cause nuisance, result in a visible film or coating on the surface of the water or on objects in the water, or otherwise adversely affect beneficial uses" Basin Plan, III-5.00.

Under the Clean Water Act (CWA), point source dischargers are required to obtain federal discharge (NPDES) permits and to comply with water quality based effluent limits (WQBELs) in NPDES permits sufficient to make progress toward the achievement of water quality standards or goals. The antibacksliding and antidegradation rules clearly spell out the interest of Congress in achieving the CWA's goal of continued progress toward eliminating all pollutant discharges. Congress clearly chose an overriding environmental interest in clean water through discharge reduction, imposition

of technological controls, and adoption of a rule against relaxation of limitations once they are established.

Upon permit reissuance, modification, or renewal, a discharger may seek a relaxation of permit limitations. However, according to the CWA, relaxation of a WQBEL is permissible only if the requirements of the antibacksliding rule are met. The antibacksliding regulations prohibit EPA from reissuing NPDES permits containing interim effluent limitations, standards or conditions less stringent than the final limits contained in the previous permit, with limited exceptions. These regulations also prohibit, with some exceptions, the reissuance of permits originally based on best professional judgment (BPJ) to incorporate the effluent guidelines promulgated under CWA §304(b), which would result in limits less stringent than those in the previous BPJ-based permit. Congress statutorily ratified the general prohibition against backsliding by enacting §§402(o) and 303(d)(4) under the 1987 Amendments to the CWA. The amendments preserve present pollution control levels achieved by dischargers by prohibiting the adoption of less stringent effluent limitations than those already contained in their discharge permits, except in certain narrowly defined circumstances.

When attempting to backslide from WQBELs under either the antidegradation rule or an exception to the antibacksliding rule, relaxed permit limits must not result in a violation of applicable water quality standards. The general prohibition against backsliding found in §402(o)(1) of the Act contains several exceptions. Specifically, under §402(o)(2), a permit may be renewed, reissued, or modified to contain a less stringent effluent limitation applicable to a pollutant *if*: (A) material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation; (B)(i) information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance; or (ii) the Administrator determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under subsection (a)(1)(B) of this section; (C) a less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is no reasonably available remedy [(e.g., Acts of God)]; (D) the permittee has received a permit modification under section 1311(c), 1311(g), 1311(h), 1311(i), 1311(k), 1311(n), or 1326(a) of this title; or (E) the permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit, and has properly operated and maintained the facilities, but has nevertheless been unable to achieve the previous effluent limitations, in which case the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).

Even if a discharger can meet either the requirements of the antidegradation rule under §303(d)(4) or one of the statutory exceptions listed in §402(o)(2), there are still limitations as to how far a permit may be allowed to backslide. Section 402(o)(3) acts as a floor to restrict the extent to which BPJ and water quality-based permit limitations may

be relaxed under the antibacksliding rule. Under this subsection, even if EPA allows a permit to backslide from its previous permit requirements, EPA may never allow the reissued permit to contain effluent limitations which are less stringent than the current effluent limitation guidelines for that pollutant, or which would cause the receiving waters to violate the applicable state water quality standard adopted under the authority of §303.49.

Federal regulations 40 CFR 122.44 (l)(1) have been adopted to implement the antibacksliding requirements of the CWA:

(l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued, interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under Sec. 122.62.)

(2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

(i) Exceptions--A permit with respect to which paragraph (l)(2) of this section applies may be renewed, reissued, or modified to contain a less stringent effluent limitation applicable to a pollutant, if:

(A) Material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation;

(B)(1) Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance; or (2) The Administrator determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under section 402(a)(1)(b);

(C) A less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is no reasonably available remedy;

(D) The permittee has received a permit modification under section 301(c), 301(g), 301(h), 301(i), 301(k), 301(n), or 316(a); or
(E) The permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit and has properly operated and maintained the facilities but has nevertheless been unable to achieve the previous effluent limitations, in which case the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).
(ii) Limitations. In no event may a permit with respect to which paragraph (1)(2) of this section applies be renewed, reissued, or modified to contain an effluent limitation which is less stringent than required by effluent guidelines in effect at the time the permit is renewed, reissued, or modified. In no event may such a permit to discharge into waters be renewed, issued, or modified to contain a less stringent effluent limitation if the implementation of such limitation would result in a violation of a water quality standard under section 303 applicable to such waters.

4. The proposed Permit incorrectly established the technology based CBOD limitations for tertiary treatment

The proposed Permit establishes an Effluent Limitation for CBOD at 10 mg/l based on the technological ability of a tertiary wastewater treatment plant. The capabilities of a tertiary treatment system are based on BOD at 10 mg/l, not CBOD. Federal Regulations for secondary 40 CFR 133.102 and equivalent to secondary treatment 40 CFR 133.105 allow for the substitution of BOD for CBOD, but at a reduced rate. For example a secondary BOD limitation of 30 mg/l converts to a 25 mg/l limitation for CBOD (40 CFR 133.102). In the CBOD test the nitrification reaction is suppressed chemically. Since the City of Stockton only partially nitrifies large errors could occur in the CBOD tests. BOD and CBOD are a measure of oxygen demanding substances. Dissolved oxygen levels in the Deep Water Ship Channel are the subject of a TMDL, however waste load allocations have not been assigned. The proposed Permit grants Stockton overly generous oxygen demanding substance allowance in assessing the capability of a tertiary treatment system to achieve only 10 mg/l CBOD. If the CBOD limitation were properly reduced to 8 mg/l; at a flow rate of 55 million gallons per day (mgd) the resulting reduction in CBOD would be 3,672 lbs/day. Federal Regulation 40 CFR 122.44 (d) requires that permits are required to contain limitations more stringent than technology based limitations where necessary to achieve applicable water quality standards and to achieve compliance in WQLSs.

5. The proposed Permit does not contain a protective effluent limitation for ammonia in violation of Federal Regulations 40 CFR 122.44 and California Water Code Section 13377

The proposed Permit contains effluent limitations for ammonia as a daily maximum and as an average monthly. There is no four day average limit for ammonia. US EPA's *Ambient Water Quality Criteria for the Protection of Freshwater Aquatic Life 1999 update for Ammonia* EPA-822-R-99-014 recommends that "the highest four-day average within the 30 day period should not exceed 2.5 times the CCC" (the chronic criterion). US EPA's ambient criteria document is the source of information used by the Regional Board to establish the limitations for ammonia; however the Regional Board has failed to utilize the complete recommendation that US EPA states is necessary to protect freshwater aquatic life. The California Water Code (CWC), Section 13377 states in part that: "...the state board or the regional boards shall...issue waste discharge requirements...which apply and ensure compliance with ...water quality control plans, or for the protection of beneficial uses..." Section 122.44(d) of 40 CFR requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. Where numeric water quality objectives have not been established, 40 CFR §122.44(d) specifies that WQBELs may be established using USEPA criteria guidance under CWA section 304(a), proposed State criteria or a State policy interpreting narrative criteria supplemented with other relevant information, or an indicator parameter. Failure to include a protective effluent limitation for ammonia in the proposed Permit violates 40 CFR 122.44 and CWC 13377.

6. The proposed Permit fails to contain mass-based effluent limits for bis(2-ethylhexyl)phthalate, chlorodibromomethane, dichlorobromomethane, cyanide, manganese, molybdenum and nitrate plus nitrite as required by Federal Regulations 40 CFR 122.45(b)

Federal Regulation, 40 CFR 122.45 (b) requires that in the case of POTWs, permit Effluent Limitations, standards, or prohibitions shall be based on design flow. Concentration is not a basis for design flow. Mass limitations are concentration multiplied by the design flow and therefore meet the regulatory requirement.

Section 5.7.1 of U.S. EPA's *Technical Support Document for Water Quality Based Toxics Control* (TSD, EPA/505/2-90-001) states with regard to mass-based Effluent Limits:

"Mass-based effluent limits are required by NPDES regulations at 40 CFR 122.45(f). The regulation requires that all pollutants limited in NPDES permits have limits, standards, or prohibitions expressed in terms of mass with three exceptions, including one for pollutants that cannot be expressed appropriately by mass. Examples of such pollutants are pH, temperature, radiation, and whole effluent toxicity. Mass limitations in terms of pounds per day or kilograms per day can be calculated for all chemical-specific toxics such as chlorine or chromium. Mass-based limits should be calculated using concentration limits at critical flows. For example, a permit limit of 10 mg/l of cadmium discharged at

an average rate of 1 million gallons per day also would contain a limit of 38 kilograms/day of cadmium.

Mass based limits are particularly important for control of bioconcentratable pollutants. Concentration based limits will not adequately control discharges of these pollutants if the effluent concentrations are below detection levels. For these pollutants, controlling mass loadings to the receiving water is critical for preventing adverse environmental impacts.

However, mass-based effluent limits alone may not assure attainment of water quality standards in waters with low dilution. In these waters, the quantity of effluent discharged has a strong effect on the instream dilution and therefore upon the RWC. At the extreme case of a stream that is 100 percent effluent, it is the effluent concentration rather than the mass discharge that dictates the instream concentration. Therefore, EPA recommends that permit limits on both mass and concentration be specified for effluents discharging into waters with less than 100 fold dilution to ensure attainment of water quality standards.”

Federal Regulations, 40 CFR 122.45 (f), states the following with regard to mass limitations:

- “(1) all pollutants limited in permits shall have limitations, standards, or prohibitions expressed in terms of mass except:
 - (i) For pH, temperature, radiation or other pollutants which cannot be expressed by mass;
 - (ii) When applicable standards and limitations are expressed in terms of other units of measurement; or
 - (iii) If in establishing permit limitations on a case-by-case basis under 125.3, limitations expressed in terms of mass are infeasible because the mass of the pollutant discharged cannot be related to a measure of operation (for example, discharges of TSS from certain mining operations), and permit conditions ensure that dilution will not be used as a substitute for treatment.

- (2) Pollutants limited in terms of mass additionally may be limited in terms of other units of measurement, and the permit shall require the permittee to comply with both limitations.”

Federal Regulations, 40 CFR 122.45 (B)(1), states the following: “In the case of POTWs, permit effluent limitations, standards, or prohibitions shall be calculated based on design flow.”

Traditional wastewater treatment plant design utilizes average dry weather flow rates for organic, individual constituent, loading rates and peak wet weather flow rates for hydraulic design of pipes, weir overflow rates, and pumps.

Increased wet weather flow rates are typically caused by inflow and infiltration (I/I) into the sewer collection system that dilutes constituent loading rates and does not add to the mass of wastewater constituents.

For POTWs priority pollutants, such as metals, have traditionally been reduced by the reduction of solids from the wastestream, incidental to treatment for organic material. Following adoption of the CTR, compliance with priority pollutants is of critical importance and systems will need to begin utilizing loading rates of individual constituents in the WWTP design process. It is highly likely that the principal design parameters for individual priority pollutant removal will be based on mass, making mass based Effluent Limitations critically important to compliance. The inclusion of mass limitations will be of increasing importance to achieving compliance with requirements for individual pollutants.

As systems begin to design to comply with priority pollutants, the design systems for POTWs will be more sensitive to similar restrictions as industrial dischargers currently face where production rates (mass loadings) are critical components of treatment system design and compliance. Currently, Industrial Pretreatment Program local limits are frequently based on mass. Failure to include mass limitations would allow industries to discharge mass loads of individual pollutants during periods of wet weather when a dilute concentration was otherwise observed, upsetting treatment processes, causing effluent limitation processes, sludge disposal issues, or problems in the collection system.

TMDLs represent a mass loading that may occur over a given time period to attain and maintain water quality standards. Mass loadings from WWTPs are critical to determining individual discharger allocations once a TMDL has been completed.

In addition to the above citations, on June 26th 2006 U.S. EPA, Mr. Douglas Eberhardt, Chief of the CWA Standards and Permits Office, sent a letter to Dave Carlson at the Central Valley Regional Water Quality Control Board strongly recommending that NPDES permit effluent limitations be expressed in terms of mass as well as concentration.

- 7. The proposed Permit contains an inadequate antidegradation analysis that does not comply with the requirements of Section 101(a) of the Clean Water Act, federal regulations 40 CFR § 131.12, the State Board’s Antidegradation**

Policy (Resolution 68-16) and California Water Code (CWC) Sections 13146 and 13247

CWC Sections 13146 and 13247 require that the Board in carrying out activities which affect water quality shall comply with state policy for water quality control unless otherwise directed by statute, in which case they shall indicate to the State Board in writing their authority for not complying with such policy. The State Board has adopted the Antidegradation Policy (Resolution 68-16), which the Regional Board has incorporated into its Basin Plan. The Regional Board is required by the CWC to comply with the Antidegradation Policy.

Section 101(a) of the Clean Water Act (CWA), the basis for the antidegradation policy, states that the objective of the Act is to “restore and maintain the chemical, biological and physical integrity of the nation’s waters.” Section 303(d)(4) of the CWA carries this further, referring explicitly to the need for states to satisfy the antidegradation regulations at 40 CFR § 131.12 before taking action to lower water quality. These regulations (40 CFR § 131.12(a)) describe the federal antidegradation policy and dictate that states must adopt both a policy at least as stringent as the federal policy as well as implementing procedures.

California’s antidegradation policy is composed of both the federal antidegradation policy and the State Board’s Resolution 68-16 (State Water Resources Control Board, Water Quality Order 86-17, p. 20 (1986) (“Order 86-17”); Memorandum from Chief Counsel William Attwater, SWRCB to Regional Board Executive Officers, “federal Antidegradation Policy,” pp. 2, 18 (Oct. 7, 1987) (“State Antidegradation Guidance”). As a state policy, with inclusion in the Water Quality Control Plan (Basin Plan), the antidegradation policy is binding on all of the Regional Boards (Water Quality Order 86-17, pp. 17-18).

Implementation of the state’s antidegradation policy is guided by the State Antidegradation Guidance, SWRCB Administrative Procedures Update 90-004, 2 July 1990 (“APU 90-004”) and USEPA Region IX, “Guidance on Implementing the Antidegradation Provisions of 40 CFR 131.12” (3 June 1987) (“Region IX Guidance”), as well as Water Quality Order 86-17.

The Regional Board must apply the antidegradation policy whenever it takes an action that will lower water quality (State Antidegradation Guidance, pp. 3, 5, 18, and Region IX Guidance, p. 1). Application of the policy does not depend on whether the action will actually impair beneficial uses (State Antidegradation Guidance, p. 6). Actions that trigger use of the antidegradation policy include issuance, re-issuance, and modification of NPDES and Section 404 permits and waste discharge requirements, waiver of waste discharge requirements, issuance of variances, relocation of discharges, issuance of cleanup and abatement orders, increases in discharges due to industrial production and/or municipal growth and/or other sources, exceptions from otherwise applicable water quality objectives, etc. (State Antidegradation Guidance, pp. 7-10, Region IX Guidance, pp. 2-3). Both the state and federal policies apply to point and

nonpoint source pollution (State Antidegradation Guidance p. 6, Region IX Guidance, p. 4).

In particular, the proposed Permit does not address the Antidegradation Policy requirements with regard to the following permit allowances:

- The proposed Permit establishes an Effluent Limitation for CBOD at 10 mg/l based on the technological ability of a tertiary wastewater treatment plant. The capabilities of a tertiary treatment system are based on BOD at 10 mg/l, not CBOD. Federal Regulations for secondary 40 CFR 133.102 and equivalent to secondary treatment 40 CFR 133.105 allow for the substitution of BOD for CBOD, but at a reduced rate. For example a secondary BOD limitation of 30 mg/l converts to a 25 mg/l limitation for CBOD (40 CFR 133.102). In the CBOD test the nitrification reaction is suppressed chemically. Since the City of Stockton only partially nitrifies large errors could occur in the CBOD tests. BOD and CBOD are a measure of oxygen demanding substances. Dissolved oxygen levels in the Deep Water Ship Channel are the subject of a TMDL, however waste load allocations have not been assigned. The proposed Permit grants Stockton overly generous oxygen demanding substance allowance in assessing the capability of a tertiary treatment system to achieve only 10 mg/l CBOD. If the CBOD limitation were properly reduced to 8 mg/l; at a flow rate of 55 million gallons per day (mgd) the resulting reduction in CBOD would be 3,672 lbs/day. Federal Regulation 40 CFR 122.44 (d) requires that permits are required to contain limitations more stringent than technology based limitations where necessary to achieve applicable water quality standards and to achieve compliance in WQLSs.
- The proposed Permit establishes for nitrate plus nitrite at 40 mg/l. At a flow rate of 55 mgd this equates to a mass of 18,360 lbs/day. Nitrogen is an oxygen demanding substance and the base for nitrate and nitrite. The impacts of allowing this level of nitrogen are not discussed in terms of the Antidegradation Policy. Denitrification, treatment to remove nitrate, is a common treatment technology and could be considered to be best practicable treatment and control of the discharge, as is required by the Antidegradation Policy. The level of 40 mg/l for nitrate plus nitrite is well above the drinking water MCL, a Basin Plan Chemical Constituents water quality objective, of 10 mg/l.
- The proposed Permit, Finding H, properly cites that the receiving stream, the San Joaquin River is a *Water Quality Limited Segment* (WQLSs) for unknown toxicity. The proposed Permit, Findings G and H, also properly cites that Federal Regulation 40 CFR 122.44 (d) requires that permit are required to contain limitations more stringent than technology based limitations where necessary to achieve applicable water quality standards and to achieve compliance in WQLSs. Proposed Permit Finding H is

incorrect however in citing that toxicity limitations are included in the proposed Permit. The proposed Permit, *C Special Provisions 2 Special Studies, Technical Reports and Additional Monitoring Requirements, a, Chronic Whole Effluent Toxicity*, requires: “For compliance with the Basin Plan’s narrative toxicity objective, this Order requires the Discharger to conduct chronic whole effluent toxicity testing...” Sampling does not limit the discharge and does not constitute a limitation. Contrary to the Findings in the proposed Permit there are not limitations for toxicity although required by Federal Regulations 40 CFR 122.44 (d) to achieve compliance with WQLSs for unknown toxicity in the receiving stream.

- The Discharger’s wastewater treatment plant includes unlined facultative ponds and wetlands. “Groundwater monitoring results obtained within the Facility has at times exceeded the applicable water quality objectives for TDS and Nitrate” (page 24). The Groundwater data, Table F-13, shows that very few constituents have been monitored, however; the groundwater has been degraded by the discharge for TDS and EC. It is not necessary to determine unaffected background water quality to show degradation from the discharge. The proposed Permit, *B Groundwater Limitations 2*, states that the limitations for the protection of groundwater do not become effective until after completion of tasks outlined in Provision VI.C.2.c. Provision VI.C.2.c allows 2.5 years to complete a study of background water quality after which and assessment of best practicable treatment and control of the discharge will be assessed under an undefined time schedule. It is reasonable to assume that the Discharger could use the 5 year life of the permit to conduct the studies required in Provision VI.C.2.c. There currently are no effective limitations in the proposed Permit protective of groundwater quality. The Antidegradation Policy discussion in the proposed Permit does not discuss groundwater impacts from the discharge or whether percolation of sewage constitutes BPTC. This discussion should also include an explanation of how the Regional Board has allowed an exemption from CCR Title 27 requirements when it is precondition to be in full compliance with the Basin Plan.

The antidegradation analysis in the proposed Permit is not simply deficient, it is literally nonexistent. The brief discussion of antidegradation requirements, in the Findings and Fact Sheet, consist only of skeletal, unsupported, undocumented conclusory statements totally lacking in factual analysis. NPDES permits must include any more stringent effluent limitation necessary to implement the Regional Board Basin Plan (Water Code 13377). The proposed Permit fails to properly implement the Basin Plan’s Antidegradation Policy.

8. The proposed Permit fails to contain a protective Effluent Limitation for Electrical Conductivity (EC) as required by 40 CFR 122.44 (d)(i)

The proposed Permit contains an Effluent Limitation for EC as an annual average of 1,300 $\mu\text{mhos/cm}$ (Effluent Limitations j); then the proposed Permit set forth tasks which if not met requires compliance with EC limitations of 700 $\mu\text{mhos/cm}$ and 1,000 $\mu\text{mhos/cm}$ seasonally. There is no water quality protective basis for the 1,300 $\mu\text{mhos/cm}$ limitation. Federal Regulations, 40 CFR 122.44 (d)(i), requires that; “Limitations must control all pollutants or pollutant parameters (either conventional, nonconventional, or toxic pollutants) which the Director determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality.” The Water Quality Control Plan (Basin Plan) for the Central Valley Region, Water Quality Objectives, page III-3.00, contains a Chemical Constituents Objective that includes Title 22 Drinking Water Maximum Contaminant Levels (MCLs) by reference. The Title 22 MCLs for EC are 900 $\mu\text{mhos/cm}$ (recommended level), 1,600 $\mu\text{mhos/cm}$ (upper level) and 2,200 $\mu\text{mhos/cm}$ (short term maximum).

The Basin Plan states, on Page III-3.00 Chemical Constituents, that “Waters shall not contain constituents in concentrations that adversely affect beneficial uses.” The Basin Plan’s “Policy for Application of Water Quality Objectives” provides that in implementing narrative water quality objectives, the Regional Board will consider numerical criteria and guidelines developed by other agencies and organizations. This application of the Basin Plan is consistent with Federal Regulations, 40CFR 122.44(d).

For EC, *Ayers R.S. and D.W. Westcott, Water Quality for Agriculture, Food and Agriculture Organization of the United Nations – Irrigation and Drainage Paper No. 29, Rev. 1, Rome (1985)*, levels above 700 $\mu\text{mhos/cm}$ will reduce crop yield for sensitive plants. The University of California, Davis Campus, Agricultural Extension Service, published a paper, dated 7 January 1974, stating that there will not be problems to crops associated with salt if the EC remains below 750 $\mu\text{mhos/cm}$.

The wastewater discharge maximum EC level discharged was 1518 $\mu\text{mhos/cm}$. Clearly the discharge exceeds the MCLs for EC presenting a reasonable potential to exceed the water quality objective. The proposed EC limitation clearly exceeds the agricultural water quality goal and the MCL for EC. The proposed Order fails to establish an effluent limitation for EC that are protective of the Chemical Constituents water quality objective. The City’s wastewater discharge increases concentrations of EC to unacceptable concentrations adversely affecting the agricultural beneficial use. The wastewater discharge not only presents a reasonable potential, but also actually causes, violation of the Chemical Constituent Water Quality Objective in the Basin Plan. The available literature regarding safe levels of EC for irrigated agriculture mandate that an Effluent Limitation for EC is necessary to protect the beneficial use of the receiving stream in accordance with the Basin Plan and Federal Regulations. Failure to establish effluent limitations for EC that are protective of the Chemical Constituents water quality objective blatantly violates the law.

Federal Regulation, 40 CFR 122.44, which mandates an effluent limitation be established if a discharge exceeds a water quality objective. MCLs are incorporated into

the Basin Plan by reference. State Board Water Quality Order 2005-005 states, in part that: “...the State Board takes official notice [pursuant to Title 23 of California Code of Regulations, Section 648.2] of the fact that operation of a large-scale reverse osmosis treatment plant would result in production of highly saline brine for which an acceptable method of disposal would have to be developed. Consequently, any decision that would require use of reverse osmosis to treat the City’s municipal wastewater effluent on a large scale should involve thorough consideration of the expected environmental effects.” The State Board does not have the authority to ignore Federal Regulation. Bay Area treatment plants have been utilized for RO brine disposal previously.

9. Effluent Limitations for specific conductivity (EC) is improperly regulated as an annual average contrary to Federal Regulations 40 CFR 122.45 (d)(2) and common sense

Federal Regulation 40 CFR 122.45 (d)(2) requires that permit for POTWs establish Effluent Limitations as average weekly and average monthly unless impracticable. The proposed Permit establishes Effluent Limitations for EC as an annual average contrary to the cited Federal Regulation. Establishing the Effluent Limitations for EC in accordance with the Federal Regulation is not impracticable; to the contrary the Central Valley Regional Board has a long history of having done so. Proof of impracticability is properly a steep slope and the Regional Board has not presented any evidence that properly and legally limiting EC is impracticable.

10. The proposed Permit contains Effluent Limitations less stringent than the existing permit contrary to the Antidegradation requirements of the Clean Water Act and Federal Regulations, 40 CFR 122.44 (l)(1)

Under the Clean Water Act (CWA), point source dischargers are required to obtain federal discharge (NPDES) permits and to comply with water quality based effluent limits (WQBELs) in NPDES permits sufficient to make progress toward the achievement of water quality standards or goals. The antidegradation and antidegradation rules clearly spell out the interest of Congress in achieving the CWA’s goal of continued progress toward eliminating all pollutant discharges. Congress clearly chose an overriding environmental interest in clean water through discharge reduction, imposition of technological controls, and adoption of a rule against relaxation of limitations once they are established.

Upon permit reissuance, modification, or renewal, a discharger may seek a relaxation of permit limitations. However, according to the CWA, relaxation of a WQBEL is permissible only if the requirements of the antidegradation rule are met. The antidegradation regulations prohibit EPA from reissuing NPDES permits containing interim effluent limitations, standards or conditions less stringent than the final limits contained in the previous permit, with limited exceptions. These regulations also prohibit, with some exceptions, the reissuance of permits originally based on best professional judgment (BPJ) to incorporate the effluent guidelines promulgated under CWA §304(b), which would result in limits less stringent than those in the previous BPJ-

based permit. Congress statutorily ratified the general prohibition against backsliding by enacting §§402(o) and 303(d)(4) under the 1987 Amendments to the CWA. The amendments preserve present pollution control levels achieved by dischargers by prohibiting the adoption of less stringent effluent limitations than those already contained in their discharge permits, except in certain narrowly defined circumstances.

When attempting to backslide from WQBELs under either the antidegradation rule or an exception to the antibacksliding rule, relaxed permit limits must not result in a violation of applicable water quality standards. The general prohibition against backsliding found in §402(o)(1) of the Act contains several exceptions. Specifically, under §402(o)(2), a permit may be renewed, reissued, or modified to contain a less stringent effluent limitation applicable to a pollutant *if*: (A) material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation; (B)(i) information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance; or (ii) the Administrator determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under subsection (a)(1)(B) of this section; (C) a less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is no reasonably available remedy [(e.g., Acts of God)]; (D) the permittee has received a permit modification under section 1311(c), 1311(g), 1311(h), 1311(i), 1311(k), 1311(n), or 1326(a) of this title; or (E) the permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit, and has properly operated and maintained the facilities, but has nevertheless been unable to achieve the previous effluent limitations, in which case the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).

Even if a discharger can meet either the requirements of the antidegradation rule under §303(d)(4) or one of the statutory exceptions listed in §402(o)(2), there are still limitations as to how far a permit may be allowed to backslide. Section 402(o)(3) acts as a floor to restrict the extent to which BPJ and water quality-based permit limitations may be relaxed under the antibacksliding rule. Under this subsection, even if EPA allows a permit to backslide from its previous permit requirements, EPA may never allow the reissued permit to contain effluent limitations which are less stringent than the current effluent limitation guidelines for that pollutant, or which would cause the receiving waters to violate the applicable state water quality standard adopted under the authority of §303.49.

Federal regulations 40 CFR 122.44 (l)(1) have been adopted to implement the antibacksliding requirements of the CWA:

(l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued, interim effluent

limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under Sec. 122.62.)

(2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

(i) Exceptions--A permit with respect to which paragraph (1)(2) of this section applies may be renewed, reissued, or modified to contain a less stringent effluent limitation applicable to a pollutant, if:

(A) Material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation;

(B)(1) Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance; or (2) The Administrator determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under section 402(a)(1)(b);

(C) A less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is no reasonably available remedy;

(D) The permittee has received a permit modification under section 301(c), 301(g), 301(h), 301(i), 301(k), 301(n), or 316(a); or

(E) The permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit and has properly operated and maintained the facilities but has nevertheless been unable to achieve the previous effluent limitations, in which case the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but

shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).

(ii) Limitations. In no event may a permit with respect to which paragraph (1)(2) of this section applies be renewed, reissued, or modified to contain an effluent limitation which is less stringent than required by effluent guidelines in effect at the time the permit is renewed, reissued, or modified. In no event may such a permit to discharge into waters be renewed, issued, or modified to contain a less stringent effluent limitation if the implementation of such limitation would result in a violation of a water quality standard under section 303 applicable to such waters.

The proposed Permit Fact Sheet, pages F-36, 37 and 38 discuss Pathogens. Page F-37 in the last paragraph states that the previous Order established Effluent Limitations for turbidity. Turbidity limitations are maintained in the proposed Permit but have been moved to Section 5f Special Provisions, page 30, they are no longer Effluent Limitations. The Fact Sheet Pathogen discussion states that infectious agents in sewage are bacteria, parasites and viruses and that tertiary treatment is necessary to effectively remove these agents. This discussion also states that turbidity limitations were originally established: "...to ensure that the treatment system was functioning properly and could meet the limits for total coliform organisms. This discussion is incorrect. First; coliform organism limitations are also an indicator parameter of the effectiveness of tertiary treatment. The coliform limitations in the proposed and past Permit are significantly lower than the Basin Plan Water Quality Objective and are based on the level of treatment recommended by the California Department of Public Health (DPH). Second; both the coliform limitations and turbidity are recommended by DPH as necessary to protect recreational and irrigated agricultural beneficial uses of the receiving water. Turbidity has no lesser standing than coliform organisms in the DPH recommendation. Section 122.44(d) of 40 CFR requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. There are no limitations for viruses and parasites in the proposed Permit, which the Regional Board has indicated, are necessary to protect the contact recreation and irrigated agricultural uses of the receiving water. Both coliform and turbidity limitations are treatment effectiveness indicators that the levels of bacteria viruses and parasites are adequately removed to protect the beneficial uses. Special Provisions are not Effluent Limitations as required by the Federal Regulations. The turbidity Effluent Limitations must be restored in accordance with the Clean Water Act and Federal regulations 40 CFR 122.44 (1)(1).

11. The proposed Permit contains effluent limitations less stringent than the existing permit contrary to the Antibracksliding requirements of the Clean Water Act and Federal Regulations, 40 CFR 122.44 (1)(1)

Under the Clean Water Act (CWA), point source dischargers are required to obtain federal discharge (NPDES) permits and to comply with water quality based

effluent limits (WQBELs) in NPDES permits sufficient to make progress toward the achievement of water quality standards or goals. The antibacksliding and antidegradation rules clearly spell out the interest of Congress in achieving the CWA's goal of continued progress toward eliminating all pollutant discharges. Congress clearly chose an overriding environmental interest in clean water through discharge reduction, imposition of technological controls, and adoption of a rule against relaxation of limitations once they are established.

Upon permit reissuance, modification, or renewal, a discharger may seek a relaxation of permit limitations. However, according to the CWA, relaxation of a WQBEL is permissible only if the requirements of the antibacksliding rule are met. The antibacksliding regulations prohibit EPA from reissuing NPDES permits containing interim effluent limitations, standards or conditions less stringent than the final limits contained in the previous permit, with limited exceptions. These regulations also prohibit, with some exceptions, the reissuance of permits originally based on best professional judgment (BPJ) to incorporate the effluent guidelines promulgated under CWA §304(b), which would result in limits less stringent than those in the previous BPJ-based permit. Congress statutorily ratified the general prohibition against backsliding by enacting §§402(o) and 303(d)(4) under the 1987 Amendments to the CWA. The amendments preserve present pollution control levels achieved by dischargers by prohibiting the adoption of less stringent effluent limitations than those already contained in their discharge permits, except in certain narrowly defined circumstances.

When attempting to backslide from WQBELs under either the antidegradation rule or an exception to the antibacksliding rule, relaxed permit limits must not result in a violation of applicable water quality standards. The general prohibition against backsliding found in §402(o)(1) of the Act contains several exceptions. Specifically, under §402(o)(2), a permit may be renewed, reissued, or modified to contain a less stringent effluent limitation applicable to a pollutant *if*: (A) material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation; (B)(i) information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance; or (ii) the Administrator determines that technical mistakes or mistaken interpretations of law were made in issuing the permit under subsection (a)(1)(B) of this section; (C) a less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is no reasonably available remedy [(e.g., Acts of God)]; (D) the permittee has received a permit modification under section 1311(c), 1311(g), 1311(h), 1311(i), 1311(k), 1311(n), or 1326(a) of this title; or (E) the permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit, and has properly operated and maintained the facilities, but has nevertheless been unable to achieve the previous effluent limitations, in which case the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).

Even if a discharger can meet either the requirements of the antidegradation rule under §303(d)(4) or one of the statutory exceptions listed in §402(o)(2), there are still limitations as to how far a permit may be allowed to backslide. Section 402(o)(3) acts as a floor to restrict the extent to which BPJ and water quality-based permit limitations may be relaxed under the antibacksliding rule. Under this subsection, even if EPA allows a permit to backslide from its previous permit requirements, EPA may never allow the reissued permit to contain effluent limitations which are less stringent than the current effluent limitation guidelines for that pollutant, or which would cause the receiving waters to violate the applicable state water quality standard adopted under the authority of §303.49.

Federal regulations 40 CFR 122.44 (1)(1) have been adopted to implement the antibacksliding requirements of the CWA:

(1) Reissued permits. (1) Except as provided in paragraph (1)(2) of this section when a permit is renewed or reissued, interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under Sec. 122.62.)

(2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

(i) Exceptions--A permit with respect to which paragraph (1)(2) of this section applies may be renewed, reissued, or modified to contain a less stringent effluent limitation applicable to a pollutant, if:

(A) Material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation;

(B)(1) Information is available which was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and which would have justified the application of a less stringent effluent limitation at the time of permit issuance; or (2) The Administrator determines that technical mistakes or mistaken

interpretations of law were made in issuing the permit under section 402(a)(1)(b);

(C) A less stringent effluent limitation is necessary because of events over which the permittee has no control and for which there is no reasonably available remedy;

(D) The permittee has received a permit modification under section 301(c), 301(g), 301(h), 301(i), 301(k), 301(n), or 316(a); or

(E) The permittee has installed the treatment facilities required to meet the effluent limitations in the previous permit and has properly operated and maintained the facilities but has nevertheless been unable to achieve the previous effluent limitations, in which case the limitations in the reviewed, reissued, or modified permit may reflect the level of pollutant control actually achieved (but shall not be less stringent than required by effluent guidelines in effect at the time of permit renewal, reissuance, or modification).

(ii) Limitations. In no event may a permit with respect to which paragraph (1)(2) of this section applies be renewed, reissued, or modified to contain an effluent limitation which is less stringent than required by effluent guidelines in effect at the time the permit is renewed, reissued, or modified. In no event may such a permit to discharge into waters be renewed, issued, or modified to contain a less stringent effluent limitation if the implementation of such limitation would result in a violation of a water quality standard under section 303 applicable to such waters.

The proposed Permit contains Effluent Limitations for bis(2-ethylhexyl)phthalate, chlorodibromomethane, dichlorobromomethane and cyanide. Mass Effluent Limitations for these constituents were included in the past NPDES permit. Mass Effluent Limitations for these constituents are necessary as discussed in the above comments. The removal of mass limitations for these constituents constitutes backsliding and violates the Clean Water Act and Federal Regulation.

12. The proposed Permit establishes effluent limitations for metals based on the hardness of the effluent as opposed to the ambient upstream receiving water hardness as required by federal regulations; the California Toxics Rule (CTR, 40 CFR 131.38(c)(4))

Federal Regulation 40 CFR 131.38(c)(4) states that: “For purposes of calculating freshwater aquatic life criteria for metals from the equations in paragraph (b)(2) of this section, for waters with a hardness of 400 mg/l or less as calcium carbonate, the actual ambient hardness of the surface water shall be used in those equations.” (Emphasis added). Attachment G, of the proposed Permit, is a summary of the reasonable potential

analysis. Footnotes No. 8, 9 and 10, of Attachment G, state that the effluent hardness was used to calculate the reasonable potential and possibly Effluent Limitations for metals (copper, cadmium, chromium, nickel and zinc).

The proposed Permit Fact Sheet, pages F-16, 17 and 18, go into great detail citing the Federal Regulation requiring the receiving water hardness be used to establish Effluent Limitations. The permit writer then cites “recent studies by several consultants” which “indicate that using the lowest receiving water hardness... is not always the most protective for the receiving water.” Despite the statement by the permit writer, there is no such evidence in the proposed Permit. It could be stated with some confidence that consultants may have a vested interest, which at times may be contrary to what is best for water quality. The ambient receiving water hardness is not presented to support the permit writer’s arguments, nor are comparative Effluent Limitation values presented to defend the unsupported statements regarding which is more protective. Once again the public is subject to a bureaucrat “knowing better” and simply choosing to ignore very clear regulatory requirements. The Regional Board staff have chosen to deliberately ignore Federal Regulations placing themselves above the law. There are procedures for changing regulations if peer reviewed science indicates the need to do so, none of which have been followed. The proposed Permit failure to include Effluent Limitations for copper, cadmium, silver and zinc based on the actual ambient hardness of the surface water is contrary to the cited Federal Regulation and must be amended to comply with the cited regulatory requirement.

13. The proposed Permit either improperly dedesignates reach of the receiving stream for beneficial uses or grants a mixing zone without a mixing zone analysis contrary to the SIP and the Basin Plan.

The proposed Permit Fact Sheet pages 19, 20 and 21 states that drinking water and irrigated agricultural intakes do not exist for quite a distance downstream of the point of discharge and that assimilative capacity exists for numerous constituents. The proposed Permit then grants an effluent limitation that exceeds the agricultural water quality goal and/or drinking water maximum contaminant level (MCL), which is a Basin Plan Chemical Constituents water quality objective. This does not protect the irrigated agriculture and drinking water beneficial uses within an unspecified reach of the receiving stream. This process either dedesignates the receiving stream for the irrigated agriculture and drinking water beneficial uses or at a minimum allows for a mixing zone without compliance with the requirements of the SIP (Section 1.4.2.2) and the Basin Plan *Policy for Application of Water Quality Objectives* (IV-16 and 17).

“A mixing zone is an area where an effluent discharge undergoes initial dilution and is extended to cover the secondary mixing in the ambient waterbody. A mixing zone is an allocated impact zone where water quality criteria can be exceeded as long as acutely toxic conditions are prevented” according to EPA’s *Technical Support Document for Water Quality-based Toxics Control* (TSD) (USEPA, 1991), (Water quality criteria must be met at the edge of a mixing zone.) Mixing zones are regions within public waters adjacent to point source discharges where pollutants are diluted and dispersed at

concentrations that routinely exceed human health and aquatic life water quality standards (the maximum levels of pollutants that can be tolerated without endangering people, aquatic life, and wildlife.) Mixing zone policies allow a discharger's point of compliance with state and federal water quality standards to be moved from the "end of the pipe" to the outer boundaries of a dilution zone. The CWA was adopted to minimize and eventually eliminate the release of pollutants into public waters because fish were dying and people were getting sick. The CWA requires water quality standards (WQS) be met in all waters to prohibit concentrations of pollutants at levels assumed to cause harm. Since WQS criteria are routinely exceeded in mixing zones it is likely that in some locations harm is occurring. The general public is rarely aware that local waters are being degraded within these mixing zones, the location of mixing zones within a waterbody, the nature and quantities of pollutants being diluted, the effects the pollutants might be having on human health or aquatic life, or the uses that may be harmed or eliminated by the discharge. Standing waist deep at a favorite fishing hole, a fisherman has no idea that he is in the middle of a mixing zone for pathogens for a sewage discharger that has not been required to adequately treat their waste.

In 1972, backed by overwhelming public support, Congress overrode President Nixon's veto and passed the Clean Water Act. Under the CWA, states are required to classify surface waters by *uses* – the beneficial purposes provided by the waterbody. For example, a waterbody may be designated as a drinking water source, or for supporting the growth and propagation of aquatic life, or for allowing contact recreation, or as a water source for industrial activities, or all of the above. States must then adopt *criteria* – numeric and narrative limits on pollution, sufficient to protect the uses assigned to the waterbody. *Uses + Criteria = Water Quality Standards (WQS)*. WQS are regulations adopted by each state to protect the waters under their jurisdiction. If a waterbody is classified for more than one use, the applicable WQS are the criteria that would protect the most sensitive use.

All wastewater dischargers to surface waters must apply for and receive a permit to discharge pollutants under the National Pollutant Discharge Elimination System (NPDES.) Every NPDES permit is required to list every pollutant the discharger anticipates will be released, and establish effluent limits for these pollutants to ensure the discharger will achieve WQS. NPDES permits also delineate relevant control measures, waste management procedures, and monitoring and reporting schedules.

It is during the process of assigning effluent limits in NPDES permits that variances such as mixing zones alter the permit limits for pollutants by multiplying the scientifically derived water quality criteria by dilution factors. The question of whether mixing zones are legal has never been argued in federal court.

Mixing zones are never mentioned or sanctioned in the CWA. To the contrary, the CWA appears to speak against such a notion:

“whenever...the discharges of pollutants from a point source...would interfere with the attainment or maintenance of

that water quality...which shall assure protection of public health, public water supplies, agricultural and industrial uses, and the protection and propagation of a balanced population of shellfish, fish and wildlife, and allow recreational activities in and on the water, effluent limitations...shall be established which can reasonably be expected to contribute to the attainment or maintenance of such water quality.”

A plain reading of the above paragraph calls for the application of effluent limitations whenever necessary to assure that *WQS will be met in all waters*. Despite the language of the Clean Water Act; US EPA adopted 40 CFR 131.13, General policies, that allows States to, at their discretion, include in their State standards, policies generally affecting their application and implementation, such as mixing zones, low flows and variances. According to EPA; (EPA, Policy and Guidance on Mixing Zones, 63 Fed Reg. 36,788 (July 7, 1998)) as long as mixing zones do not eliminate beneficial uses in the whole waterbody, they do not violate federal regulation or law. California has mixing zone policies included in individual Water Quality Control Plans (Basin Plans) and the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (2005) permitting pollutants to be diluted before being measured for compliance with the state’s WQS.

Federal Antidegradation regulations at 40 CFR 131.12 require that states protect waters at their present level of quality and that all beneficial uses remain protected. The corresponding State Antidegradation Policy, Resolution 68-16, requires that any degradation of water quality not unreasonably affect present and anticipated beneficial uses. Resolution 68-16 further requires that: “Any activity which produces or may produce or increase volume or concentration of waste and which discharges or proposes to discharge to existing high quality waters will be required to meet waste discharge requirements which will result in the best practicable treatment or control of the discharge necessary to assure that (a) a pollution or nuisance will not occur and (b) the highest water quality consistent with the maximum benefit to the people of the State will be maintained.”

- Pollution is defined in the California Water Code as an alteration of water quality to a degree which unreasonably affects beneficial uses. In California, Water Quality Control Plans (Basin Plans) contain water quality standards and objectives which are necessary to protect beneficial uses. The Basin Plan for California’s Central Valley Regional Water Board states that: “According to Section 13050 of the California Water Code, Basin Plans consist of a designation or establishment for the waters within a specified area of beneficial uses to be protected, water quality objectives to protect those uses, and a program of implementation needed for achieving the objectives. State law also requires that Basin Plans conform to the policies set forth in the Water Code beginning with Section 13000 and any state policy for water quality control. Since beneficial uses, together with their corresponding water quality objectives, can be defined

per federal regulations as water quality standards, the Basin Plans are regulatory references for meeting the state and federal requirements for water quality control (40 CFR 131.20).”

- Nuisance is defined in the California Water Code as anything which is injurious to health, indecent, offensive or an obstruction of the free use of property which affects an entire community and occurs as a result of the treatment or disposal of waste.

The Antidegradation Policy (Resolution 68-16) allows water quality to be lowered as long as beneficial uses are protected (pollution or nuisance will not occur), best practicable treatment and control (BPTC) of the discharge is provided, and the degradation is in the best interest of the people of California. Water quality objectives were developed as the maximum concentration of a pollutant necessary to protect beneficial uses and levels above this concentration would be considered pollution. The Antidegradation Policy does not allow water quality standards and objectives to be exceeded. Mixing zone are regions within public waters adjacent to point source discharges where pollutants are diluted and dispersed at concentrations that routinely exceed water quality standards.

The Antidegradation Policy (Resolution 68-16) requires that best practicable treatment or control (BPTC) of the discharge be provided. Mixing zones have been allowed in lieu of treatment to meet water quality standards at the end-of-the-pipe prior to discharge. To comply with the Antidegradation Policy, the trade of receiving water beneficial uses for lower utility rates must be in the best interest of the people of the state and must also pass the test that the Discharger is providing BPTC. By routinely permitting excessive levels of pollutants to be legally discharged, mixing zones act as an economic disincentive to Dischargers who might otherwise have to design and implement better treatment mechanisms. Although the use of mixing zones may lead to individual, short-term cost savings for the discharger, significant long-term health and economic costs may be placed on the rest of society. An assessment of BPTC, and therefore compliance with the Antidegradation Policy, must assess whether treatment of the wastestream can be accomplished, is feasible, and not simply the additional costs of compliance with water quality standards. A BPTC case can be made for the benefits of prohibiting mixing zones and requiring technologies that provide superior waste treatment and reuse of the wastestream.

EPA’s Water Quality Standards Handbook states that: “It is not always necessary to meet all water quality criteria within the discharge pipe to protect the integrity of the waterbody as a whole.” The primary mixing area is commonly referred to as the zone of initial dilution, or ZID. Within the ZID acute aquatic life criteria are exceeded. To satisfy the CWA prohibition against the discharge of toxic pollutants in toxic amounts, regulators assume that if the ZID is small, significant numbers of aquatic organisms will not be present in the ZID long enough to encounter acutely toxic conditions. EPA recommends that a ZID not be located in an area populated by non-motile or sessile

organisms, which presumably would be unable to leave the primary mixing area in time to avoid serious contamination.

Determining the impacts and risks to an ecosystem from mixing pollutants with receiving waters at levels that exceed WQS is extremely complex. The range of effects pollutants have on different organisms and the influence those organisms have on each other further compromises the ability of regulators to assess or ensure “acceptable” short and long-term impacts from the use of mixing zones. Few if any mixing zones are examined prior to the onset of discharging for the potential effects on impacted biota (as opposed to the physical and chemical fate of pollutants in the water column). Biological modeling is especially challenging – while severely toxic discharges may produce immediately observable effects, long-term impacts to the ecosystem can be far more difficult to ascertain. The effects of a mixing zone can be insidious; impacts to species diversity and abundance may be impossible to detect until it is too late for reversal or mitigation.

The *CALIFORNIA CONSTITUTION, ARTICLE 10, WATER, SEC. 2* states that: “It is hereby declared that because of the conditions prevailing in this State the general welfare requires that the water resources of the State be put to beneficial use to the fullest extent of which they are capable, and that the waste or unreasonable use or unreasonable method of use of water be prevented, and that the conservation of such waters is to be exercised with a view to the reasonable and beneficial use thereof in the interest of the people and for the public welfare. The right to water or to the use or flow of water in or from any natural stream or water course in this State is and shall be limited to such water as shall be reasonably required for the beneficial use to be served, and such right does not and shall not extend to the waste or unreasonable use or unreasonable method of use or unreasonable method of diversion of water. Riparian rights in a stream or water course attach to, but to no more than so much of the flow thereof as may be required or used consistently with this section, for the purposes for which such lands are, or may be made adaptable, in view of such reasonable and beneficial uses; provided, however, that nothing herein contained shall be construed as depriving any riparian owner of the reasonable use of water of the stream to which the owner's land is riparian under reasonable methods of diversion and use, or as depriving any appropriator of water to which the appropriator is lawfully entitled. This section shall be self-executing, and the Legislature may also enact laws in the furtherance of the policy in this section contained.” The granting of a mixing zone is an unreasonable use of water when proper treatment of the wastestream can be accomplished to meet end-of-pipe limitations. Also contrary to the California Constitution, a mixing zone does not *serve the beneficial use*; to the contrary, beneficial uses are degraded within the mixing zone.

The Central Valley Regional Water Quality Control Board’s Basin Plan, page IV-16.00, requires the Regional Board use EPA’s *Technical Support Document for Water Quality Based Toxics Control (TSD)* in assessing mixing zones. The TSD, page 70, defines a first stage of mixing, close to the point of discharge, where complete mixing is determined by the momentum and buoyancy of the discharge. The second stage is defined by the TSD where the initial momentum and buoyancy of the discharge are

diminished and waste is mixed by ambient turbulence. The TSD goes on to state that in large rivers this second stage mixing may extend for miles. There are drinking water intakes, and proposed intakes, downstream of the wastewater discharge, which could be impacted prior to the pollutants from the discharge, are completely mixed. The TSD, Section 4.4, requires that if complete mix does not occur in a short distance mixing zone monitoring and modeling must be undertaken.

The State's *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays and Estuaries of California* (SIP), Section 1.4.2.2, contains requirements for a mixing zone study which must be analyzed before a mixing zone is allowed for a wastewater discharge. Properly adopted state Policy requirements are not optional. The proposed Effluent Limitations in the proposed Permit are not supported by the scientific investigation that is required by the SIP and the Basin Plan.

SIP Section 1.4.2.2 requires that a mixing zone shall not:

1. Compromise the integrity of the entire waterbody.
2. Cause acutely toxic conditions to aquatic life.
3. Restrict the passage of aquatic life.
4. Adversely impact biologically sensitive habitats.
5. Produce undesirable aquatic life.
6. Result in floating debris.
7. Produce objectionable color, odor, taste or turbidity.
8. Cause objectionable bottom deposits.
9. Cause Nuisance.
10. Dominate the receiving water body or overlap a different mixing zone.
11. Be allowed at or near any drinking water intake.

The proposed Permit's mixing zones have not addressed a single required item of the SIP. To the contrary the San Joaquin River is already 303d listed for numerous constituents. A very clear unaddressed requirement (SIP Section 1.4.2.2) for mixing zones is that the point(s) in the receiving stream where the applicable criteria must be met shall be specified in the proposed Permit. The "edge of the mixing zone" has not been defined.

The SIP states, on page 16, that dilution credits and mixing zones for incompletely mixed discharges shall be considered by the Regional Board only after the Discharger has completed an independent mixing zone study. Mixing zones or dilution credits were improperly allowed for dibromochloromethane, bromodichloromethane, manganese, molybdenum and nitrate plus nitrite. Few mixing zones are adequately evaluated to determine whether the modeling exercise was in fact relevant or accurate, or monitored over time to assess the impacts of the mixing zone on the aquatic environment. The sampling of receiving waters often consists of analyzing one or two points where the mixing zone boundary is supposed to be – finding no pollution at the mixing zone boundary is often considered proof that mixing has been "successful" when in fact the sampling protocol might have missed the plume altogether.

14. The proposed Permit fails to contain protective effluent limitations for aluminum in accordance with Federal Regulations 40 CFR 122.44, US EPA’s interpretation of the regulation, and California Water Code, Section 13377

Aluminum in the effluent has been measured and the Regional Board has found that there is a reasonable potential to exceed water quality standards. Aluminum has been shown to be toxic to freshwater aquatic life. Freshwater Aquatic habitat is a beneficial use of the receiving stream. The Basin Plan contains a narrative water quality objective for toxicity that states in part that “[a]ll waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life” (narrative toxicity objective). U.S. EPA developed National Recommended Ambient Water Quality Criteria for protection of freshwater aquatic life for aluminum. The recommended four-day average (chronic) and one-hour average (acute) criteria for aluminum are 87 mg/l and 750 mg/l, respectively.

The argument has been repeatedly made that US EPA’s 87 ug/l chronic criterion was developed using low pH and hardness testing and should not be used. The proposed Permit cites the ambient criteria document as it relates to the low hardness and pH but fails to follow the final EPA recommendation that the criteria be used unless a cite specific criteria is developed. As is stated in EPA’s development document, (Ambient Water Quality Criteria for Aluminum, EPA 440/5-86-008) the pH was in the range 6.5 to 6.6. The hardness was below 20 mg/l; however the proposed Permit does not contain a discharge limitation for hardness and numerous effluents and receiving waters within the Central Valley experience hardness at or below this level. Despite the hardness and pH values used in the development of the criteria; the simple fact is that U.S. EPA recommends that application of the ambient criteria as necessary to be protective of the aquatic beneficial uses of receiving waters in lieu of site-specific criteria.

Based on information included in analytical laboratory reports submitted by the Discharger, aluminum in the discharge has a reasonable potential to cause or contribute to an in-stream excursion above a level necessary to protect aquatic life, and, therefore to violate the Basin Plan’s narrative toxicity objective.

Federal Regulations, 40 CFR 122.44 (d)(i), requires that; “Limitations must control all pollutants or pollutant parameters (either conventional, nonconventional, or toxic pollutants) which the Director determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard, including State narrative criteria for water quality.” US EPA has interpreted 40 CFR 122.44(d) in *Central Tenets of the National Pollutant Discharge Elimination System (NPDES) Permitting Program* (Factsheets and Outreach Materials, 08/16/2002) that although States will likely have unique implementation policies there are certain tenets that may not be waived by State procedures. These tenets include that “where valid, reliable, and representative effluent data or instream background data are available they MUST be used in applicable reasonable potential and limits derivation calculations. Data may not be arbitrarily discarded or ignored.” The

California Water Code (CWC), Section 13377 states in part that: "...the state board or the regional boards shall...issue waste discharge requirements... which apply and ensure compliance with ...water quality control plans, or for the protection of beneficial uses..." Section 122.44(d) of 40 CFR requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. A water quality standard for Failure to include an effluent limitation for aluminum based on the chronic criteria in the proposed permit violates 40 CFR 122.44 and CWC 13377.

15. The Proposed Permit contains an inadequate Reasonable Potential Analysis by using incorrect statistical multipliers

Federal regulations, 40 CFR § 122.44(d)(1)(ii), state "when determining whether a discharge causes, has the reasonable potential to cause, or contributes to an in-stream excursion above a narrative or numeric criteria within a State water quality standard, the permitting authority shall use procedures which account for existing controls on point and nonpoint sources of pollution, **the variability of the pollutant or pollutant parameter in the effluent**, the sensitivity of the species to toxicity testing (when evaluating whole effluent toxicity), and where appropriate, the dilution of the effluent in the receiving water." Emphasis added.

Attachment G: The reasonable potential analysis fails to consider the statistical variability of data and laboratory analyses as explicitly required by the federal regulations. The proposed Permit utilizes the simple method of whether the existing maximum effluent concentration has exceeded the water quality standard instead of the required multiplier factors necessary to properly evaluate reasonable potential. The procedures for computing variability are detailed in Chapter 3, pages 52-55, of USEPA's *Technical Support Document For Water Quality-based Toxics Control*.

The reasonable potential analyses are flawed and must be recalculated. The fact that the SIP illegally ignores this fundamental requirement does not exempt the Regional Board from its obligation to consider statistical variability in compliance with federal regulations.

Thank you for considering these comments. If you have questions or require clarification, please don't hesitate to contact us.

Sincerely,



Bill Jennings, Executive Director
California Sportfishing Protection Alliance